

t	p	r'	r''	v'	v''	h'	h''	r	s'	s''
°C	bar	kg/dm³	kg/m³	dm³/kg	dm³/kg	kJ/kg	kJ/kg	kJ/kg	kJ/(kgK)	kJ/(kgK)
-50,00	0,86	1,327	4,80	0,753	208,16	135,08	334,21	199,13	0,7389	1,6319
-45,00	1,10	1,312	6,04	0,762	165,66	141,22	337,19	195,97	0,7665	1,6257
-40,00	1,39	1,296	7,51	0,772	133,24	147,43	340,14	192,71	0,7938	1,6201
-35,00	1,73	1,280	9,24	0,781	108,21	153,71	343,06	189,35	0,8207	1,6152
-30,00	2,13	1,263	11,28	0,792	88,66	160,07	345,93	185,86	0,8473	1,6108
-25,00	2,60	1,247	13,66	0,802	73,23	166,53	348,76	182,23	0,8735	1,6069
-20,00	3,14	1,230	16,41	0,813	60,93	173,08	351,53	178,45	0,8994	1,6034
-15,00	3,77	1,212	19,60	0,825	51,03	179,71	354,24	174,53	0,9249	1,6003
-10,00	4,50	1,194	23,26	0,838	42,99	186,43	356,88	170,45	0,9502	1,5975
-5,00	5,32	1,175	27,46	0,851	36,42	193,23	359,44	166,21	0,9752	1,5950
0,00	6,24	1,156	32,27	0,865	30,99	200,00	361,92	161,92	1,0000	1,5926
5,00	7,29	1,136	37,76	0,880	26,48	207,09	364,29	157,21	1,0247	1,5904
10,00	8,46	1,116	44,04	0,896	22,71	214,15	366,55	152,40	1,0493	1,5882
15,00	9,77	1,094	51,22	0,914	19,52	221,31	368,67	147,36	1,0739	1,5861
20,00	11,22	1,071	59,43	0,933	16,83	228,61	370,64	142,03	1,0986	1,5838
25,00	12,83	1,048	68,86	0,955	14,52	236,05	372,42	136,36	1,1235	1,5813
30,00	14,60	1,022	79,74	0,978	12,54	243,70	373,97	130,27	1,1487	1,5785
35,00	16,55	0,995	92,36	1,005	10,83	251,59	375,26	123,66	1,1743	1,5753
40,00	18,70	0,966	107,16	1,035	9,33	259,80	376,21	116,41	1,2004	1,5714
45,00	21,04	0,934	124,71	1,071	8,02	268,40	376,73	108,33	1,2272	1,5666